



Annual CCR Fugitive Dust Control Report

December 2016

This report fulfills the requirements of 40 CFR §257.80(c), necessitating the filing of an Annual Coal Combustion Residual (CCR) Fugitive Dust Control Report. Included are descriptions of control actions, record(s) of citizen complaints, and description(s) of corrective measures.

To date, the Kansas City Board of Public Utilities (KCBPU) Nearman Creek Power Station (NCPS) has had no fugitive dust emission issues.

1.0 Description of Control Actions

The following methods are employed by NCPS as Fugitive Dust Control Measures:

1.1 Bottom Ash Handling

The ash is sluiced wet via pipeline to the CCR surface impoundment therefore there are no potential CCR fugitive dust emission sources.

1.2 Flue Gas Desulfurization (FGD) Ash Handling

Fly ash is pneumatically transported from the bottom of the Pulse Jet Fabric Filter (PJFF) and temporarily stored in silos at KCBPU until hauled to a landfill or beneficial use application. All ash is either wetted via pugmill or unloaded dry with a telescopic chute, with over suction, minimizing any fugitive dust emissions. The telescopic chute lowers into haul trucks. All haul trucks are enclosed.

1.3 Access and Haul Roads

A gravel access road leads from the generating station to the CCR surface impoundment, which is utilized by plant personnel for routine daily operations and maintenance activities. Speed limit signs are posted to lower any potential for fugitive dust emissions.



1.4 CCR Surface Impoundment

The bottom ash is wet sluiced via a pipeline to the CCR surface impoundment. To date, no fugitive dust emissions have occurred at the CCR surface impoundment.

2.0 Citizen Complaints

No citizen complaints have been filed.

3.0 Summary of Corrective Measures

No corrective measures have been required for fugitive dust control.

Fugitive dust control measures taken at NCPS are effective and continuously monitored.

Director of Environmental Services

Name:

A handwritten signature in blue ink is written over a horizontal line. The signature is stylized and appears to consist of several loops and a long horizontal stroke extending to the right.